



# 连云港亚新钢铁有限公司 LIANYUGANG YAXIN STEEL CO.LTD. 热轧带肋钢筋产品质量证明书

编号: YXGT04B-10023A.3



HOT ROLLED BARS PRODUCTS QUALITY IMPERATIVEP AND GUARANTEE CERTIFICATE

执行标准 (STANDARD):	GB/T 1499.2--2018	证明书编号 (NUMBER):	20240620203958	地址:	江苏省灌南县堆沟港镇化工园区亚新路
收货单位 (PURCHASER):	浙江建设商贸物流有限公司-钧宸	到站 (DESTINATION):	恒基	邮编 (ZIPCODE):	223523
合同号 (CONTRACTNO):	202406200008	车号 (TRAIN NO):	苏G32089	电话 (PHONE):	(0518)-83995777/80927927
产品名称 (PRODUCT):	热轧带肋钢筋	生产许可证 (LICENSE NO):	(苏) XK05-001-00616	传真 (FAX):	(0518)-80927927
通过ISO9001:2015质量管理体系认证 编号: 25321QZ0074R1L		日期 (DATE):	Thu Jun 20 17:21:51 CST 2024		

序号	炉批号	牌号	规格 (mm)	标牌重量 (kg)	捆数 (件)	化学成分 (%)							力学性能 (Mpa)						外形尺寸			重量偏差	弯曲试验	金相组织	表面质量	综合判定	
						C	Si	Mn	P	S	V	Ceq	屈服强度	抗拉强度	强屈比	屈屈比	伸长率	总伸长率	横肋高	肋间距	横肋末端间隙						
1	42406202016	HRB400	φ8	6762	3	0.24	0.36	1.17	0.021	0.024	0	0.44	465 460	0 0	630	0.00 0.00	0.00 0.00	26.0 29.0	0.0 0.0	0.7 0.7	5.5 5.5	1.6 1.6	0.9	180° 弯曲试验	F+P	无缺陷	合格
合计: TOTAL				6762	3	说明: Ceq=C+Mn/6+(Cr+v+Mo)/5+(Cu+Ni)/15																					

备注:

- |                                  |   |
|----------------------------------|---|
| 1、本证明书所列钢材经按标准及合同规定检验判定合格。       | 3、验收中发现品质问题不符, 请将证明书, 批号, 钢号, 规格等通知我们, 以便 |
| 2、Ni, Cr, Cu元素含量及成品化学成分全部符合标准规定。 | 4、本证明书不得伪造, 本证明书复印件无复印单位加盖的鲜章无效。          |

NOTES:

- |   |   |
|---|---|
| 1. ACCORDING TO STANDARD AND CONTRACT STIPULATION, SECTION STEEL IN THE CERTIFICATE HAVE BEEN INSPCETED WITH SAPTISFACTION. | 3. IF YOU FIND THE SECTION STEEL AREN'T UP TO STANDARD, INFORMING US THE CERTIFICATH NUMBER, BATCH NUMBER, AND GRADE EDC. |
| 2. THE COMPOSITION OF Ni, Cr, Cu AND CHECK ANALYSIS ACCORD WITH STANDARD.   | 4. DO NOT FORGED THE SECTION STEEL QUALITY CERTIFICATE, THE COPYS ARE UNAVAILABLE.  |


生产车间:  
WORKSHOP  
P

轧钢4号线

制单人:  
TABULATOR

三号码头

审核人:  
CHECKING



检验部门章:  
EXAMINATION CHING STAMP