

质量证明书

CERTIFICATE OF QUALITY

ANHUI LANGXI HONGTAI IRON & STEEL CO. LTD

GAOJIA VILLAGE, XINFATOWN, LANGXI COUNTY, ANHUI PROVINCE

邮 编:242100

ZIP CODE:242100

VERIFIED BY QUALITY, ENVIRONMENT, SAFETY AND MEASUREMENT

MANAGEMENT SYSTEM CERTIFICATION



订货单位 CUSTOMER				证明书编号 CERTIFICATE NO		20250403039		证明书日期 ISSUE DATE		2025. 04. 3		产品名称 PRODUCT NAME		钢筋混凝土用热轧带肋钢筋 Steel for the reinforcement of concrete Hot rolled ribbed bars									
生产许可证号 PRODUGTON LICENSES		(皖)XK05-001-00006		执行标准 LMPLEMENT STANDARD		GB 1499. 2-2024		合同号 CONTRACTNO				牌号 GRADE		HRB400E									
序号	炉 (批) 号 DURNACEBATCH NUMBER	规格及重量 SPECIFICS			化学成分 (%) CHEMICAL ANALYSIS							力学和工艺性能 MBCHANICAL PROPERTIES								金相 组织	重量 偏差		
		规格 SIZE (mm)	件数 PCS	重量 (吨)	C	Si	Mn	P	S	V	Ceq	屈服强度 Rel (Mpa)	抗拉强度 Rm (Mpa)	R ⁰ m/ R ⁰ eL	R ⁰ eL /Rel	断后 伸长率 A %	最大力总 延伸率 Agt %	弯曲性 能 180° D=4d	反向弯曲 性能 正弯90° 反弯20° D=5d				
1	25030898	8	17	37.125	0.25	0.37	0.71	0.008	0.029	0.001	0.39	437	586	1.34	1.09	20	12.9	完好	完好	合格	合格		
												450	593	1.32	1.13	20	12.9	完好	完好	合格	合格		
警告：本证明书文字手写、复印无效。 WARNING:THIS CERTIFICATE IS WRITTEN IN HANDWRITING COPY IS INVALID				备注:1. 钢筋标记:/4E/HX/6/34006/、/4E/HX/8/34006/、 /4E/HX/10/34006/、 /4E/HX/12/34006/; STEEL BAR MARKED:/4E/HX/6/34006/、/4E/HX/8/34006/、 /4E/HX/10/34006/、 /4E/HX/12/34006/; 2. 表面质量和外形尺寸：合格。 SURFACE QUALITY/SIZE: QUALIFFIED.																			

安徽省和县海泰钢铁有限公司
质量证明书专用章

检验专用章

审核：