

质量证明书

CERTIFICATE OF QUALITY



安徽省郎溪县鸿泰钢铁有限公司

ANHUI LANGXI HONGTAI IRON & STEEL CO. LTD

安徽省郎溪县新发镇高家村

GAOJIA VILLAGE, XINFA TOWN, LANGXI COUNTY, ANHUI PROVINCE

电 话：0563-5233333

邮 编:242100

TEL: 0563-5233333

ZIP CODE:242100

通过质量、环境、职业健康安全和测量管理体系认证

VERIFIED BY QUALITY, ENVIRONMENT, SAFETY AND MEASUREMENT

MANAGEMENT SYSTEM CERTIFICATION



订货单位 CUSTOMER				证明书编号 CERTIFICATE NO		20250403118		证明书日期 ISSUE DATE		2025.04.3		产品名称 PRODUCT NAME		钢筋混凝土用热轧带肋钢筋 Steel for the reinforcement of concrete Hot rolled ribbed bars									
生产许可证号 PRODUGTON LICENSES		(皖)XK05-001-00006		执行标准 LMPLEMENT STANDARD		GB 1499.2-2024		合同号 CONTRACTNO				牌号 GRADE		HRB400E									
序号	炉(批)号 DURNACEBATCH NUMBER	规格及重量 SPECIFICS			化学成分(%) CHEMICAL ANALYSIS							力学和工艺性能 MBCHANICAL PROPERTIES								金相 组织	重量 偏差		
		规格 SIZE (mm)	件数 PCS	重量 (吨)	C	Si	Mn	P	S	V	Ceq	屈服强度 Rel (Mpa)	抗拉强度 Rm (Mpa)	R ⁰ m/ R ⁰ eL	R ⁰ eL /Rel	断后 伸长率 A %	最大力总 延伸率 Agt %	弯曲性 能 180° D=4d	反向弯曲 性能 正弯90° 反弯20° D=5d				
1	25030853	10	29	66.084	0.24	0.36	0.80	0.008	0.027	0.001	0.40	451	609	1.35	1.13	22	13.1	完好	完好	合格	合格		
												447	609	1.36	1.12	22	12.9	完好	完好	合格	合格		
警告：本证明书文字手写、复印无效。 WARNING:THIS CERTIFICATE IS WRITTEN IN HANDWRITING COPY IS INVALID				备注:1. 钢筋标记:/4E/HX/6/34006/、/4E/HX/8/34006/、/4E/HX/10/34006/、/4E/HX/12/34006/; STEEL BAR MARKED:/4E/HX/6/34006/、/4E/HX/8/34006/、/4E/HX/10/34006/、/4E/HX/12/34006/; 2. 表面质量和外形尺寸：合格。 SURFACE QUALITY/SIZE: QUALIFFIED.																			

安徽省滁州市
凤阳县鸿泰钢铁有限公司
质量证明书专用章
检验专用章

审核：