



连云港亚新钢铁有限公司
LIANYUGANG YAXIN STEEL CO.LTD.
热轧带肋钢筋产品质量证明书

HOT ROLLED BARS PRODUCTS QUALITY IMPERATIVEP AND GUARANTEE CERTIFICATE



编号: YXGT04B-10023A.3

执行标准(STANDARD):	GB/T 1499. 2--2018	证明书编号(NUMBER):	20240430230020	地址:	江苏省灌南县堆沟港镇化工园区亚新路1号
收货单位(PURCHASER):	上海盛和国际贸易有限公司	到站(DESTINATION):	中远化工	邮编(ZIPCODE):	223523
合同号(CONTARCTNO):	202404300012	车号(TRAIN NO):	苏GC9660	电话(PHONE):	(0518)-83995777/80927927
产品名称(PRODUCT):	热轧带肋钢筋	生产许可证(LICENSE NO):	(苏) XK05-001-00616	传真(FAX):	(0518)-80927927
通过ISO9001:2015质量管理体系认证 编号: 25321QZ0074R1L		日期(DATE):	2024-04-30		

序号	炉批号	牌号	规格 (mm)	标牌重量 (kg)	捆数 (件)	化学成分 (%)							力学性能 (Mpa)						外形尺寸			重量 偏差	弯曲试验		金相 组织	表面 质量	综合判定		
						C	Si	Mn	P	S	V	Ceq	屈服 强度	抗拉 强度	强屈 比	屈屈 比	伸长 率	总伸 长率	横肋 高	肋间 距	横肋 末端 间隙		180° 弯曲 试验	反弯 试验					
													ReL	Rp0.2	Rm	Rm/Re	ReL/R ^a	A/%	Agt/%	mm	mm		mm	%					
1	32404290765	HRB400E	φ8	4494	2	0.25	0.37	1.18	0.032	0.029	0	0.46	480 475	0 0	655 655	1.36 1.38	1.20 1.19	29.0 29.0	13.1 11.7	0.8 0.8	5.6 5.6	1.8 1.8	2.3	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格	
2	32404290763	HRB400E	φ8	6780	3	0.24	0.37	1.18	0.026	0.026	0	0.45	470 470	0 0	620 625	1.32 1.33	1.18 1.18	28.0 29.0	11.0 12.1	0.6 0.6	5.6 5.6	1.8 1.8	1.2	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格	
3	32404280761	HRB400E	φ8	22528	10	0.23	0.37	1.15	0.018	0.026	0	0.43	465 470	0 0	635 635	1.37 1.35	1.16 1.18	26.0 26.0	12.1 12.4	0.6 0.6	5.5 5.5	1.8 1.7	0.3	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格	
4	32404290764	HRB400E	φ8	4510	2	0.24	0.35	1.15	0.026	0.026	0	0.44	460 440	0 0	620 600	1.35 1.36	1.15 1.10	27.0 28.0	11.7 11.6	0.7 0.7	5.6 5.6	1.8 1.8	1.4	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格	
5	32404280762	HRB400E	φ8	11275	5	0.25	0.36	1.17	0.022	0.024	0	0.46	450 440	0 0	630 595	1.40 1.35	1.13 1.10	25.0 27.0	12.3 12.5	0.6 0.6	5.5 5.5	1.7 1.7	0.8	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格	
合计: TOTAL				49587	22	说明: Ceq=C+Mn/6+(Cr+v+Mo)/5+(Cu+Ni)/15																							

备注:

- 1、本证明书所列钢材经按标准及合同规定检验判定合格。
- 2、Ni, Cr, Cu元素含量及成品化学成分全部符合标准规定。
- NOTES:
1. ACCORDING TO STANDARD AND CONTRACT STIPULATION, SECTION STEEL IN THE CERTIFICATE HAVE BEEN INSPCETED WITH SAPTISFACTION.
- 2.THE COMPOSITION OF Ni,Cr,Cu AND CHECK ANALYSIS ACCORD WITH STANDARD.
- 3、验收中发现品质问题不符, 请将证明书, 批号, 钢号, 规格等通知我们, 以便复
- 4、本证明书不得伪造, 本证明书复印件无复印单位加盖的鲜章无效。
- 3.IF YOU FIND THE SECTION STEEL AREN'T UP TO STANDARD, INFORMING US THE CERTIFICATH NUMBER,BATCHNUMBER, AND GRADE EDC.
- 4.DO NOT FORGED THE SECTION STEEL QUALITY CERTIFICATE, THE COPYS ARE UNAVAILABLE.

生产车间: WORKSHO P

制单人: TABULATOR

审核人: CHECKING

检验部门章: EXAMINATION CHING STAMP

轧钢3号线

二号码头

产品质量专用章