



连云港亚新钢铁有限公司

LIANYUGANG YAXIN STEEL CO.LTD.

热轧带肋钢筋产品质量证明书

编号: YXGT04B-10023A.3



执行标准(STANDARD): GB1499. 2-2024 证明书编号(NUMBER): 20241230133028 地址: 江苏省灌南县堆沟港镇化工园区亚新路1号
收货单位(PURCHASER): 南通铭开盛金属材料有限公司 到站(DESTINATION): 海安 邮编(ZIPCODE): 223523
合同号(CONTRACTNO): 202412300006 车号(TRAIN NO): 苏G98860 电话(PHONE): (0518)-83995777/80927927
产品名称(PRODUCT): 热轧带肋钢筋 生产许可证(LICENSE NO): (苏) XK05-001-00616 传真(FAX): (0518)-80927927
通过ISO9001:2015质量管理体系认证 注册号: 25324QZ0009R2L 日期(DATE): 2024-12-30

序号	炉批号	牌号	规格 (mm)	标牌重量 (kg)	捆数 (件)	化学成分(%)							力学性能 (Mpa)			外形尺寸			重量 偏差	弯曲试验 180° 弯曲试验	金相 组织	表面 质量	综合 判定
						C	Si	Mn	P	S	V	Ceq	屈服 强度	抗拉 强度	伸长 率	横肋 高	肋间 距	横肋末端 间隙					
													ReL	Rm	A/%	mm	mm	mm					
1	32412303711	HRB400	Φ 10	2270	1	0. 25	0. 36	1. 19	0. 025	0. 024	0	0. 46	470 460	655 650	23. 0 27. 0	0. 8 0. 8	7. 0 7. 0	2. 1 2. 1	2. 1	6支无裂纹	F+P	无缺陷	合格
2	32412293709	HRB400	Φ 10	29540	13	0. 24	0. 37	1. 18	0. 021	0. 024	0	0. 45	450 450	610 610	25. 0 24. 0	0. 8 0. 8	7. 0 7. 0	2. 2 2. 2	0. 9	6支无裂纹	F+P	无缺陷	合格
3	32412303710	HRB400	Φ 10	18102	8	0. 25	0. 36	1. 15	0. 020	0. 026	0	0. 45	480 475	655 650	24. 0 23. 0	0. 7 0. 7	7. 0 7. 0	2. 0 2. 0	1. 9	6支无裂纹	F+P	无缺陷	合格
合计: TOTAL				49912	22	说明: Ceq=C+Mn/6+(Cr+v+Mo)/5+(Cu+Ni)/15																	

备注:

- 1、本证明书所列钢材经按标准及合同规定检验判定合格。
2、Ni, Cr, Cu元素含量及成品化学成分全部符合标准规定。
NOTES:
1. ACCORDING TO STANDARD AND CONTRACT STIPULATION, SECTION STEEL IN THE CERTIFICATE HAVE BEEN INSPCETED WITH SAPTISFACTION.
2.THE COMPOSITION OF Ni,Cr,Cu AND CHECK ANALYSIS ACCORD WITH STANDARD.
- 3、验收中发现品质问题不符, 请将证明书, 批号, 钢号, 规格等通知我们, 以便
4、本证明书不得伪造, 本证明书复印件无复印单位加盖的鲜章无效。
3.IF YOU FIND THE SECTION STEEL IN UP TO STANDARD, INFORMING US THE CERTIFICATH NUMBER, BATCH NUMBER, AND GRADE EDC.
4.DO NOT FORGED THE SECTION STEEL QUALITY CERTIFICATE, THE COPS ARE UNAVAILABLE.

生产车间:
WORKSHOP

轧钢3号线

制单人:
TABULATION

冷星星

审核人:
CHECKING

陈世斌

产品质量检验部门章:
EXAMINATION CHING STAMP