



连云港亚新钢铁有限公司
LIANYUGANG YAXIN STEEL CO.LTD.
热轧光圆钢筋产品质量证明书

编号: YXGT04B-10023A.3



执行标准(STANDARD): GB/T 1499.1--2017 证明书编号(NUMBER): 20240601173014 地址: 江苏省灌南县堆沟港镇化工园区亚新路1号
收货单位(PURCHASER): 上海盛友贸易有限公司-航友 到站(DESTINATION): 淞南库 邮编(ZIPCODE): 223523
合同号(CONTRACTNO): 202406010016 车号(TRAIN NO): 苏GS2009 电话(PHONE): (0518)-83995777/80927927
产品名称(PRODUCT): 热轧光圆钢筋 生产许可证(LICENSE NO): (苏)XK05-001-00616 传真(FAX): (0518)-80927927
通过ISO9001:2015质量管理体系认证 编号: 25321QZ0074R1L 日期(DATE): 2024-06-01

序号	炉批号	牌号	规格 (mm)	标牌重量 (kg)	捆数 (件)	化学成分(%)					力学性能(Mpa)				尺寸		重量 偏差	金相 组织	表面质 量	180° 弯曲 试验	综合 判定
						C	Si	Mn	P	S	Ceq	屈服 强度	抗拉 强度	伸长 率	总伸 长率	不圆度					
												ReL	Rm	A/%	Agt/%	mm	%				
1	124052801734	HPB300	φ10	9256	4	0.21	0.20	0.82	0.019	0.023	0	355 370	530 555	31.0 28.0	0.0 0.0	0.2 0.2	-1	F+P	无缺陷	6支无 裂纹	合格
2	124052801732	HPB300	φ10	9259	4	0.23	0.20	0.83	0.022	0.023	0	375 380	550 550	32.0 30.0	0.0 0.0	0.2 0.2	-1	F+P	无缺陷	6支无 裂纹	合格
3	124052901735	HPB300	φ10	4631	2	0.23	0.20	0.82	0.018	0.021	0	355 370	540 550	34.0 33.0	0.0 0.0	0.1 0.2	-1	F+P	无缺陷	6支无 裂纹	合格
4	124052801733	HPB300	φ10	27789	12	0.22	0.20	0.82	0.024	0.030	0	350 355	535 530	30.0 31.0	0.0 0.0	0.1 0.1	-2	F+P	无缺陷	6支无 裂纹	合格
合计: TOTAL				50935	22	说明: Ceq=C+Mn/6+(Cr+v+Mo)/5+(Cu+Ni)/15															

备注:

- 1、本证明书所列钢材经按标准及合同规定检验判定合格。
2、Ni, Cr, Cu元素含量及成品化学成分全部符合标准规定。
3、验收中发现品质问题不符, 请将证明书, 批号, 钢号, 规格等通知我们, 以便复查。
4、本证明书不得伪造, 本证明书复印件无复印单位加盖的鲜章无效。

NOTES:

1. ACCORDING TO STANDARD AND CONTRACT STIPULATION, SECTION STEEL IN THE CERTIFICATE HAVE BEEN INSPCTED WITH
2.THE COMPOSITION OF Ni,Cr,Cu AND CHECK ANALYSIS ACCORD WITH STANDARD.
3.IF YOU FIND THE SECTION STEEL AREN'T UP TO STANDARD, INFORMING US THE CERTIFICATH NUMBER,BATCH NUMBER AND GRADE ETC.
4.DO NOT FORGED THE SECTION STELL QUALITY CERTIFICATE, THE COPYS ARE UNAVAILABLE.

生产车间:

WORKSHOP

轧钢6号线

制单人:

TABULATOR

二号码头

审核人:

CHECKING

检验部门章:

EXAMINATION CHING STAMP

