



连云港亚新钢铁有限公司
LIANYUGANG YAXIN STEEL CO.LTD.
热轧带肋钢筋产品质量证明书

HOT ROLLED BARS PRODUCTS QUALITY IMPERATIVEP AND GUARANTEE CERTIFICATE



编号: YXGT04B-10023A.3

执行标准 (STANDARD):	GB/T 1499. 2--2018	证明书编号 (NUMBER):	20240531170019	地址:	江苏省灌南县堆沟港镇化工园区亚新路1号
收货单位 (PURCHASER):	连云港聚瑞国际贸易有限公司-盛和	到站 (DESTINATION):	中远化工	邮编 (ZIPCODE):	223523
合同号 (CONTRACTNO):	202405310010	车号 (TRAIN NO):	苏G76171	电话 (PHONE):	(0518)-83995777/80927927
产品名称 (PRODUCT):	热轧带肋钢筋	生产许可证 (LICENSE NO):	(苏) XK05-001-00616	传真 (FAX):	(0518)-80927927
通过ISO9001:2015质量管理体系认证 编号: 25321QZ0074R1L		日期 (DATE):	2024-05-31		

序号	炉批号	牌号	规格 (mm)	标牌重量 (kg)	捆数 (件)	化学成分 (%)							力学性能 (Mpa)						外形尺寸			重量 偏差	弯曲试验		金相 组织	表面 质量	综合判 定			
						C	Si	Mn	P	S	V	Ceq	屈服 强度		抗拉 强度	强屈 比	屈屈 比	伸长 率	总伸 长率	横肋 高	肋间 距		横肋 末端 间隙	180° 弯曲 试验				反弯 试验		
													ReL	Rp0.2	Rm	Rm/ReL	ReL/R ⁰	A/%	Agt/%	mm	mm		mm	%						
1	32405301220	HRB400E	Φ 12	15775	7	0. 24	0. 42	1. 41	0. 030	0. 020	0. 031	0. 49	470 460	0 0	635 630	1. 35 1. 37	1. 18 1. 15	23. 0 21. 0	11. 3 11. 1	0. 8 0. 8	7. 9 7. 9	2. 5 2. 5	-1. 9	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格		
2	32405301219	HRB400E	Φ 12	4516	2	0. 24	0. 40	1. 39	0. 032	0. 023	0. 032	0. 49	475 475	0 0	635 630	1. 34 1. 33	1. 19 1. 19	24. 0 23. 0	11. 0 11. 2	0. 8 0. 8	7. 9 7. 9	2. 5 2. 5	-2. 1	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格		
3	32405301221	HRB400E	Φ 12	20262	9	0. 23	0. 41	1. 38	0. 030	0. 023	0. 029	0. 48	470 465	0 0	640 630	1. 36 1. 35	1. 18 1. 16	23. 0 24. 0	11. 6 12. 1	0. 8 0. 8	7. 8 7. 8	2. 4 2. 4	-0. 9	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格		
4	32405311222	HRB400E	Φ 12	9020	4	0. 23	0. 42	1. 38	0. 024	0. 018	0. 031	0. 48	445 440	0 0	615 620	1. 38 1. 41	1. 11 1. 10	23. 0 21. 0	12. 1 11. 7	0. 7 0. 7	7. 7 7. 7	2. 4 2. 4	-2. 9	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格		
合计: TOTAL				49573	22	说明: Ceq=C+Mn/6+(Cr+v+Mo)/5+(Cu+Ni)/15																								

备注:

- 1、本证明书所列钢材经按标准及合同规定检验判定合格。
- 2、Ni, Cr, Cu元素含量及成品化学成分全部符合标准规定。
- NOTES:
1. ACCORDING TO STANDARD AND CONTRACT STIPULATION, SECTION STEEL IN THE CERTIFICATE HAVE BEEN INSPCETED WITH SAPTISFACTION.
- 2.THE COMPOSITION OF Ni,Cr,Cu AND CHECK ANALYSIS ACCORD WITH STANDARD.
- 3、验收中发现品质问题不符, 请将证明书, 批号, 钢号, 规格等通知我们, 以便复
- 4、本证明书不得伪造, 本证明书复印件无复印单位加盖的鲜章无效。
- 3.IF YOU FIND THE SECTION STEEL AREN'T UP TO STANDARD, INFORMING US THE CERTIFICATH NUMBER,BATCH NUMBER, AND GRADE EDC.
- 4.DO NOT FORGED THE SECTION STEEL QUALITY CERTIFICATE, THE COPYS ARE UNAVAILABLE.

生产车间: WORKSHO P

制单人: TABULATOR

审核人: CHECKING

检验部门章: EXAMINATION CHING STAMP

轧钢3号线

三号码头

产品质量专用章