



连云港亚新钢铁有限公司
LIANYUGANG YAXIN STEEL CO.LTD.
热轧带肋钢筋产品质量证明书

HOT ROLLED BARS PRODUCTS QUALITY IMPERATIVEP AND GUARANTEE CERTIFICATE

编号: YXGT04B-10023A.3



执行标准(STANDARD):	GB/T 1499.2--2018	证明书编号(NUMBER):	20240610170004	地址:	江苏省灌南县堆沟港镇化工园区亚新路1号
收货单位(PURCHASER):	连云港聚瑞国际贸易有限公司-盛和	到站(DESTINATION):	中远化工	邮编(ZIPCODE):	223523
合同号(CONTRACTNO):	202406100006	车号(TRAIN NO):	苏G98860	电话(PHONE):	(0518)-83995777/80927927
产品名称(PRODUCT):	热轧带肋钢筋	生产许可证(LICENSE NO):	(苏) XK05-001-00616	传真(FAX):	(0518)-80927927
通过ISO9001:2015质量管理体系认证 编号: 25321QZ0074R1L		日期(DATE):	2024-06-10		

序号	炉批号	牌号	规格 (mm)	标牌重量 (kg)	捆数 (件)	化学成分 (%)							力学性能 (Mpa)						外形尺寸			重量 偏差	弯曲试验		金相 组织	表面 质量	综合判定	
						C	Si	Mn	P	S	V	Ceq	屈服强度		抗拉强度	强屈比	屈屈比	伸长率	总伸长率	横肋高	肋间距		横肋末端 间隙	180° 弯曲 试验				反弯 试验
													ReL	Rp0.2														
1	42406101877	HRB400E	φ 8	26997	12	0.24	0.37	1.19	0.032	0.021	0	0.45	450 450	0 0	615 615	1.37 1.37	1.13 1.13	27.0 27.0	11.9 12.1	0.7 0.7	5.5 5.5	1.6 1.6	0.8	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格
2	42406101875	HRB400E	φ 8	11240	5	0.24	0.38	1.16	0.021	0.021	0	0.45	460 455	0 0	630 625	1.37 1.37	1.15 1.14	25.0 27.0	12.0 11.9	0.8 0.8	5.5 5.5	1.7 1.7	2.3	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格
3	42406101874	HRB400E	φ 8	4499	2	0.23	0.39	1.15	0.025	0.018	0	0.43	440 445	0 0	605 610	1.38 1.37	1.10 1.11	27.0 26.0	12.1 11.9	0.8 0.8	5.5 5.5	1.6 1.6	0.2	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格
4	42406101876	HRB400E	φ 8	4486	2	0.23	0.38	1.18	0.028	0.021	0	0.44	450 460	0 0	615 620	1.37 1.35	1.13 1.15	27.0 28.0	12.1 13.0	0.8 0.8	5.5 5.5	1.5 1.6	0.5	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格
5	32405271177	HRB400E	φ 8	2258	1	0.25	0.36	1.17	0.038	0.030	0	0.46	460 475	0 0	625 650	1.36 1.37	1.15 1.19	27.0 28.0	13.1 11.6	0.6 0.6	5.5 5.5	1.6 1.6	2	6支无 裂纹	6支无 裂纹	F+P	无缺 陷	合格
合计：TOTAL				49480	22	说明： Ceq=C+Mn/6+(Cr+v+Mo)/5+(Cu+Ni)/15																						

备注:

- 1、本证明书所列钢材经按标准及合同规定检验判定合格。
- 2、Ni, Cr, Cu元素含量及成品化学成分全部符合标准规定。
- NOTES:
1. ACCORDING TO STANDARD AND CONTRACT STIPULATION, SECTION STEEL IN THE CERTIFICATE HAVE BEEN INSPCETED WITH SAPTISFACTION.
- 2.THE COMPOSITION OF Ni,Cr,Cu AND CHECK ANALYSIS ACCORD WITH STANDARD.
- 3、验收中发现品质问题不符, 请将证明书, 批号, 钢号, 规格等通知我们, 以便复
- 4、本证明书不得伪造, 本证明书复印件无复印单位加盖的鲜章无效。
- 3.IF YOU FIND THE SECTION STEEL AREN'T UP TO STANDARD, INFORMING US THE CERTIFICATH NUMBER,BATCHNUMBER, AND GRADE EDC.
- 4.DO NOT FORGED THE SECTION STEEL QUALITY CERTIFICATE, THE COPYS ARE UNAVAILABLE.

生产车间: WORKSHO P

制单人: TABULATOR

二号码头

审核人: CHECKING

检验部门章: EXAMINATION CHING STAMP