



连云港亚新钢铁有限公司  
LIANYUGANG YAXIN STEEL CO.LTD.  
热轧光圆钢筋产品质量证明书

编号: YXGT04B-10023A.3



执行标准(STANDARD): GB/T 1499.1--2017 证明书编号(NUMBER): 20240609143010 地址: 江苏省灌南县堆沟港镇化工园区亚新路1号  
收货单位(PURCHASER): 连云港聚瑞国际贸易有限公司-盛和A 到站(DESTINATION): 江阴丰亿库 邮编(ZIPCODE): 223523  
合同号(CONTRACTNO): 202406090009 车号(TRAIN NO): 苏GM5188 电话(PHONE): (0518)-83995777/80927927  
产品名称(PRODUCT): 热轧光圆钢筋 生产许可证(LICENSE NO): (苏)XK05-001-00616 传真(FAX): (0518)-80927927  
通过ISO9001:2015质量管理体系认证 编号: 25321QZ0074R1L 日期(DATE): 2024-06-09

| 序号       | 炉批号          | 牌号     | 规格<br>(mm) | 标牌重量<br>(kg) | 捆数<br>(件) | 化学成分 (%)                             |      |      |       |       |     | 力学性能 (Mpa) |            |              |            | 尺寸         |   | 重量<br>偏差 | 金相<br>组织 | 表面质<br>量  | 180°<br>弯曲<br>试验 | 综合<br>判定 |
|----------|--------------|--------|------------|--------------|-----------|--------------------------------------|------|------|-------|-------|-----|------------|------------|--------------|------------|------------|---|----------|----------|-----------|------------------|----------|
|          |              |        |            |              |           | C                                    | Si   | Mn   | P     | S     | Ceq | 屈服<br>强度   | 抗拉<br>强度   | 伸长<br>率      | 总伸<br>长率   | 不圆度        |   |          |          |           |                  |          |
|          |              |        |            |              |           |                                      |      |      |       |       |     | ReL        | Rm         | A/%          | Agt/%      | mm         | % |          |          |           |                  |          |
| 1        | 22406081296  | HPB300 | φ 10       | 7003         | 3         | 0.23                                 | 0.21 | 0.80 | 0.018 | 0.033 | 0   | 390<br>355 | 570<br>530 | 32.0<br>28.0 | 0.0<br>0.0 | 0.2<br>0.2 | 0 | F+P      | 无缺陷      | 6支无<br>裂纹 | 合格               |          |
| 2        | 22406091309  | HPB300 | φ 10       | 13985        | 6         | 0.24                                 | 0.21 | 0.83 | 0.022 | 0.017 | 0   | 360<br>360 | 530<br>525 | 29.0<br>30.0 | 0.0<br>0.0 | 0.3<br>0.3 | 0 | F+P      | 无缺陷      | 6支无<br>裂纹 | 合格               |          |
| 3        | 124030400548 | HPB300 | φ 10       | 2319         | 1         | 0.22                                 | 0.25 | 0.79 | 0.029 | 0.019 | 0   | 350<br>350 | 520<br>520 | 30.0<br>30.0 | 0.0<br>0.0 | 0.3<br>0.3 | 1 | F+P      | 无缺陷      | 6支无<br>裂纹 | 合格               |          |
| 4        | 22406081297  | HPB300 | φ 10       | 23272        | 10        | 0.22                                 | 0.22 | 0.84 | 0.023 | 0.028 | 0   | 370<br>370 | 540<br>535 | 30.0<br>29.0 | 0.0<br>0.0 | 0.2<br>0.2 | 0 | F+P      | 无缺陷      | 6支无<br>裂纹 | 合格               |          |
| 合计：TOTAL |              |        |            | 46579        | 20        | 说明：Ceq=C+Mn/6+(Cr+v+Mo)/5+(Cu+Ni)/15 |      |      |       |       |     |            |            |              |            |            |   |          |          |           |                  |          |

备注:

- 1、本证明书所列钢材经按标准及合同规定检验判定合格。  
2、Ni, Cr, Cu元素含量及成品化学成分全部符合标准规定。  
3、验收中发现品质问题不符, 请将证明书, 批号, 钢号, 规格等通知我们, 以便复查。  
4、本证明书不得伪造, 本证明书复印件无复印单位加盖的鲜章无效。

NOTES:

1. ACCORDING TO STANDARD AND CONTRACT STIPULATION, SECTION STEEL IN THE CERTIFICATE HAVE BEEN INSPCTED WITH  
2. THE COMPOSITION OF Ni, Cr, Cu AND CHECK ANALYSIS ACCORD WITH STANDARD.  
3. IF YOU FIND THE SECTION STEEL AREN'T UP TO STANDARD, INFORMING US THE CERTIFICATH NUMBER, BATCH NUMBER AND GRADE ETC.  
4. DO NOT FORGED THE SECTION STELL QUALITY CERTIFICATE, THE COPYS ARE UNAVAILABLE.

生产车间:

WORKSHOP

轧钢2号线/轧钢6号线

制单人:

TABULATOR

三号码头

审核人:

CHECKING

检验部门章:

EXAMINATION CHING STAMP

